

**BUILDING DEPARTMENT**  
**SUMPTER TOWNSHIP**  
**23480 Sumpter Road**  
**Belleville, MI 48111**

To schedule inspections (Building, Electrical, Mechanical, Plumbing)  
Call 734-461-6201 Ext. 233 Monday – Friday 24-hour notice REQUIRED  
Memorial Day through Labor Day 8:00am – 4:00pm  
All other times 9:00am – 5:00pm

**CHECK LIST FOR TYPICAL ITEMS TO BE DONE BEFORE THE FOLLOWING  
INSPECTIONS ARE PERFORMED**

1. Install factory frost free sillcocks with built in vacuum breaker or add vacuum breaker to outside hose connection.
2. Install air chambers for plumbing fixtures.
3. Install pipe angers at required distances.
4. Install fire stop and nail plates for water and DWV piping.
5. **TABLE FITTINGS FOR CHANGE IN DIRECTION** no sanitary tees shall be used for vertical to horizontal or horizontal-to-horizontal connections for sanitary drainage systems.
6. All work must meet current State of Michigan Construction Codes and Requirements.

**CHECK LIST FOR TYPICAL ITEMS TO BE DONE BEFORE THE FOLLOWING  
INSPECTIONS ARE PERFORMED**

1. Minimum 6” clearance to combustible material for single wall vent connectors for furnace and water heater.
2. No connections for gas piping inside furnace cabinet (unions, couplings, etc.)
3. Union, shut-off valve, and drip leg must be installed for water heater and furnace gas connection. Install shut off valves for all appliances.
4. Combustion air shall be provided for enclosed appliance rooms.
5. Maintain minimum clearance for exhauster terminations of high efficiency appliances from doors, windows, and gas meter or regulator (LP & Natural) per code or manufacture instructions.
6. Flexible duct connectors shall be limited to 14’ in length with minimum flame spread 25 or less – minimum smoke 50 or less and shall not penetrate a firewall, floor, or ceiling.
7. All work must meet State of Michigan Construction Codes and Requirements.